

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
HILLSIDE MEMORIAL PARK AND MORTUARY
(WELL CONSTRUCTION AND PUMP TEST, WELL NO. 3)

NPDES NO. CAG994001
CI-8237

FACILITY ADDRESS

6001 Centinela Avenue
Culver City, CA 90045

FACILITY MAILING ADDRESS

6001 Centinela Avenue
Culver City, CA 90045

PROJECT DESCRIPTION:

The Hillside Memorial Park and Mortuary proposes to discharge groundwater generated during the construction of a new groundwater well at the above-referenced facility. Well development and aquifer testing will be performed after the completion of the well. A desilting tank will be installed to clarify water before discharge.

VOLUME AND DESCRIPTION OF DISCHARGE:

Up to 1.7 mgd of groundwater will be discharged during well construction, well development, and aquifer/pumping test. It will be necessary to discharge at this rate during the pumping test so as to properly size the well pump. Well development and aquifer tests will be completed within 10 days after the well construction. The analytical results of groundwater samples from adjacent well indicate that the groundwater discharge will meet effluent limits without treatment. The groundwater will be discharged to Centinela Creek (Latitude: 33° 59' 20", Longitude: 118° 23' 00"), thence to Ballona Creek, a water of the United States.

FREQUENCY OF DISCHARGE:

The discharge will be temporary and intermittent. The discharge will occur during the month of April 2001 that will last for 10 days.

REUSE OF WATER:

There is no feasible reuse options for the water. Therefore, the extracted groundwater will be discharged to Ballona Creek.

California Environmental Protection Agency

 Recycled Paper

Our mission is to preserve and enhance the quality of California's water resources for the benefit of present and future generations.